

# DECLARATION OF CONFORMITY

No. S.CE/EN/0587/V2/2015/513



KANLUX SA, ul, Objazdowa 1-3, 41-922 Radzionków (POLAND) herewith declares that the product:

## LED DOWNLIGHT FITTING

Type / Types: - KATRO LED 13W-WW-W, KATRO LED 13W-WW-SR, KATRO LED 13W-NW-W,

KATRO LED 13W-NW-SR, KATRO LED 18W-ww-w, KATRO LED 18W-WW-SR, KATRO LED 18W-NW-W, KATRO LED 18W-NW-SR, KATRO LED 23W-WW-SR, KATRO LED 23W-NW-SR, KATRO LED 23W-ww-w, KATRO LED 23W-NW-W, ROUND A LED 13W-ww-w, ROUND A LED 13W-WW-SR, ROUND A LED 13W-NW-W,

ROUND A LED 13W-NW-SR, ROUND A LED 18W-ww-w, ROUND A LED 18W-WW-SR, ROUND A LED 18W-NW-W, ROUND A LED 18W-NW-SR, ROUND A LED 23W-WW-SR,

ROUND A LED 23W-NW-SR, ROUND A LED 23W-ww-w, ROUND A LED 23W-NW-W

Trade mark: Kanlux/

Basic parameters: 220-240b<sup>ac</sup>; 50/60Hz; class II; IP44/IP20; 1 M,

18W, 23W is in conformity with the provisions of the following EC

directive(s)

(including all applicable amendments):

Directive (WD) -2006/95/EC

Directive (EMC) -2004/108/EC

Directive (RoHS) - 2011/65/EC

Directive (EuP) - 2009/125/EC

references of standards and/or technical specifications applied for this declaration of conformity:

EN 60598-1:2008 +AI :2009

EN 60598-2-2:2012

EN 62471 :2008

EN 61547:2009

EN 61000-3-2:2006 +AI :2009 +A2:2009

EN 61000-3-3:2013

EN 55015:2013

EN 50581 :2012

Additional information:

Kanlux S.A. has an implemented Quality Management system according to norm ISO 9001  
:2008 confirmed by ISO certificate PI-8000069 issued by Bureau Veritas Certification  
Polska Sp. z O.O. Last two digits of the year in which the CE marking was affixed: 15  
NWP/4563-4566, NWP/4662, NWP/4663; ID 0587; S.CE/513

  
Kierownik Laboratorium Badawczego      Dyrektor Działu Technicznego      Specjalista ds. Wdrożeń i Certyfikacji Produktów  
Krzysztof Żurek      Dariusz Staniczek      Adam Walicki  
.....  
Kierownik      S.A.

Radzionków, 27003.2015

name and function of the signatory

[www.kanlux.pl](http://www.kanlux.pl)

Kanlux S.A. Nt- KRS 0000286139 • Sad Rejonowy w Gliwicach, X Wydział Gospodarczy KRS ul. Objazdowa 1-3, 41-922 Radzionków, Polska NIP: • REGON: 240672104w  
calo<ci Kapitał zakładowy: zł opłacony tel. /32/388 74 00, fax /32/388 74 99, e-mail: kanlux@kanlux.pl ING BANK SLASKI O/BYOM: 82 1050 1230 1000 0022 5379 7878