

DECLARATION OF CONFORMITY

No. S.CE/EN/0643/V1/2015/561



KANLUX SA, ul. Objazdowa 1-3, 41-922 Radzionków (POLAND)

herewith declares that the product:

RESIDUAL-CURRENT CIRCUIT BREAKER

Type / types: **KRD6-2/25/30, KRD6-2/40/30, KRD6-2/63/30,
KRD6-4/25/30, KRD6-4/40/30, KRD6-4/63/30,
KRD6-4/100/30, KRD6-4/40/300, KRD6-2/25/30-A,
KRD6-2/40/30-A, KRD6-4/25/30-A, KRD6-4/40/30-A**

Trade mark:



Basic parameters: $U_c = 230V \sim (1P+N), 400V \sim (3P+N); I_n = 25A, 40A, 63A;$
 $I_{\Delta n} = 30mA, 300mA; I_{nc} = 6000A; I_m = 500A$

is in conformity with the provisions of the following EC directive(s)
(including all applicable amendments):

Directive (LVD) – 2006/95/EC

Directive (RoHS) – 2011/65/EC

references of standards and/or technical specifications applied for this declaration of conformity:

EN 61008-1:2012 +A1:2014 +A2:2014

EN 61008-2-1:1994 +A11:1998

EN 50581:2012

Additional information:

Kanlux S.A. has an implemented Quality Management system according to norm **ISO 9001:2008**
confirmed by ISO certificate PL8000069 issued by Bureau Veritas Certification Polska Sp. z o.o.

Last two digits of the year in which the **CE** marking was affixed: **15**

NWP/5698, NWP/5699, NWP/5700, NWP/5701; ID 0643; S.CE/561

Radzionków, 20.10.2015

www.kanlux.pl

Kanlux SA

ul. Objazdowa 1-3, 41-922 Radzionków, Polska

tel. /32/388 74 00, fax /32/388 74 99, e-mail: kanlux@kanlux.pl

Kanlux S.A.
Dyrektor Działu Technicznego
Dariusz Staniczek
Kierownik Laboratorium Badawczego
Krzysztof Żurek
Kanlux S.A.
Specjalista ds. Wdrożenia
i Certyfikacji Produktów
Adam Wabnick
name and function of the signatory

Nr KRS 0000286139 • Sąd Rejonowy w Gliwicach, X Wydział Gospodarczy KRS

NIP: 645-243-27-93 • REGON: 240672104

Kapitał zakładowy: 35 500 000 zł opłacony w całości

ING BANK SŁĄSKI O/BYOM: 82 1050 1230 1000 0022 5379 7878