

DECLARATION OF CONFORMITY

No. S.CE/EN/0314/V2/2013/248

**KANLUX S.A., ul. Objazdowa 1-3, 41-922 Radzionków (POLAND)**

herewith declares that the product:

LED EMERGENCY FITTING

Type / types:

ENTER LED DOUBLE-3H

Trade mark:

Kanlux

Basic parameters:

220-240V~, 50/60Hz; class II; IP20; LED: 4W;
normal mode & emergency mode: 3h**is in conformity with the provisions of the following EC directive(s)**
(including all applicable amendments):**Directive (LVD) – 2006/95/EC****Directive (EMC) – 2004/108/EC****Directive (RoHS) – 2011/65/EC**references of standards and/or technical specifications applied for this declaration
of conformity:**EN 60598-1:2008 +A11:2009****EN 60598-2-22:1998 +A1:2003 +A2:2005****EN 55015:2006 +A1:2007 +A2:2009****EN 61000-3-2:2006 +A1:2009 +A2:2009****EN 61000-3-3:2008****EN 61547:2009****Additional information:**Kanlux S.A. has an implemented Quality Management system according to norm **ISO 9001:2008**
confirmed by ISO certificate PL8000069 issued by Bureau Veritas Certification Polska Sp. z o.o.Last two digits of the year in which the CE marking was affixed: **09****NWP/1133; ID0314; S.CE/248****Radzionków, 13.06.2013**

Kanlux S.A.
Kierownik Działu Technicznego
Dariusz Staniczek
Dariusz Staniczek

Kanlux S.A.
Specjalista ds. Wdrożenia i Certyfikacji Produktów
Adam Wabnic
Adam Wabnic

Kanlux S.A.
Kierownik Laboratorium Badawczego
Krzysztof Żurek
Krzysztof Żurek

.....
name and function of the signatory