

# DECLARATION OF CONFORMITY

No. S.CE/EN/0640/V1/2015/560

**KANLUX SA, ul. Objazdowa 1-3, 41-922 Radzionków (POLAND)**

herewith declares that the product:

## MINIATURE CIRCUIT BREAKER

Type / types: **KMB6-B1/1, KMB6-B2/1, KMB6-B6/1, KMB6-B10/1, KMB6-B13/1, KMB6-B16/1, KMB6-B20/1, KMB6-B25/1, KMB6-B32/1, KMB6-B40/1, KMB6-B6/3, KMB6-B10/3, KMB6-B16/3, KMB6-B20/3, KMB6-B25/3, KMB6-B32/3, KMB6-B40/3, KMB6-B50/3, KMB6-B63/3, KMB6-C4/1, KMB6-C6/1, KMB6-C10/1, KMB6-C16/1, KMB6-C20/1, KMB6-C25/1, KMB6-C32/1, KMB6-C40/1, KMB6-C6/3, KMB6-C10/3, KMB6-C16/3, KMB6-C20/3, KMB6-C25/3, KMB6-C32/3, KMB6-C40/3, KMB6-C50/3, KMB6-C63/3**

Trade mark:



Basic parameters:

$U_c = 230/400V \sim (1P), 400V \sim (3P); I_n = 1..63A; I_{nc} = 6000A;$   
B-, C- type; Energy limiting class - 3

is in conformity with the provisions of the following EC directive(s)  
(including all applicable amendments):

**Directive (LVD) – 2006/95/EC****Directive (RoHS) – 2011/65/EC**

references of standards and/or technical specifications applied for this declaration of conformity:

**EN 60898-1:2003 +A1:2004 +A11:2005 +A12:2008 +A13:2012****EN 50581:2012****Additional information:**

Kanlux S.A. has an implemented Quality Management system according to norm **ISO 9001:2008**  
confirmed by ISO certificate PL8000069 issued by Bureau Veritas Certification Polska Sp. z o.o.

Last two digits of the year in which the **CE** marking was affixed: **15****NWP/5709, NWP/5710, NWP/5714, NWP/5715; ID 0640; S.CE/560****Radzionków, 19.10.2015**

**Kanlux S.A.**  
Dyrektor Działu Technicznego  
*Dariusz Staniczek*

**Kanlux S.A.**  
Kierownik Laboratorium Badawczego  
*Krzysztof Żurek*

**Kanlux S.A.**  
Specjalista ds. Wdrożenia  
i Certyfikacji Produktów  
*Adam Wabnic*

.....  
name and function of the signatory**www.kanlux.pl**